

S.P.V.V.S'S
**G.P.PORWAL ARTS, COMMERCE AND V.V.SALIMATH SCIENCE
COLLEGE, SINDGI – 586 128** (Dist : Vijayapur. Karnataka State)

Affiliated to Rani Channamma University, Belagavi

Accredited at 'B' Grade (2.42 CGPA) by NAAC

E-mail: gppprincipal@gmail.com Web: www.gppvvs.ac.in Ph: 08488-221244 Mobile :
9611032604

2022-23

To
The Principal
GPP& VVS College
Sindagi

Subject : Permission to visit Water Purification Unit, Sindagi
Ref No:As per Rani Channamma University Syllabus, Belagavi

Respected sir

We the faculty of department of Botany along with BSc I semester students kindly request you to give the permission to visit the water purification unit at Sindagi on 13/12/22 for Practical experimental demonstrations and field observations as it is made compulsory according to Rani Channamma University syllabus . Therefore, we kindly request you to give permission to visit. Hope the authority will consider and oblige.

Thanking you.

Sindagi
Date : 10/12/22

Yours faithfully



S.S.Muttinpendimath


Coordinator IQAC


Principal,
G.P.Porwal Arts, Comm. &
V.V.Salimath Sc. College
& P. G. Centre, SINDAGI

DEPARTMENT OF BOTANY

(Jyoti Angadi)



G.P.PORWAL ARTS, COMMERCE AND V.V.SALIMATH SCIENCE
COLLEGE, SINDGI – 586 128 (Dist : Vijayapur. Karnataka State)

Affiliated to Rani Channamma University, Belagavi

Accredited at 'B' Grade (2.42 CGPA) by NAAC

E-mail: gppprincipal@gmail.com Web: www.gppvvs.ac.in Ph: 08488-221244 Mobile : 9611032604

2022-23

Date: 11/12 /2022

Academic Year: 2021-22

To,
Head,
Department of Botany

Sub: Permission for visit water purification Unit.
Ref: Your letter dated 10/12 /2022

Sir/Madam,

With reference to subject cited above I herewith permit you for visit to water purification unit for B.Sc. I semester students.

Thanking you,

Place: Sindgi

Date: 11/12 /2022

Coordinator, IQAC

HEAD
Dept. of Botany
G.P.P. & V.V.S. College
SINDGI - 586 128

Co-ordinator IQAC
G. P. Porwal Arts, Comm & V. V. Salimath
Science College, SINDGI-586128. Dt:Vijayapur

Principal,
G. P. Porwal Arts, Comm. &
V. V. Salimath Sc. College,
SINDGI-586128. College Code: 5234

S.P.V.V.S'S
G.P.PORWAL ARTS, COMMERCE AND V.V.SALIMATH SCIENCE
COLLEGE, SINDGI – 586 128 (Dist : Vijayapur. Karnataka State)

Affiliated to Rani Channamma University, Belagavi

Accredited at 'B' Grade (2.42 CGPA) by NAAC

E-mail: gppprincipal@gmail.com Web: www.gppvvs.ac.in Ph: 08488-221244 Mobile :
9611032604

To,
The Chief Officer,
Town Municipal Corporation
Sindagi

Subject: Permission to Visit Water Purification Unit, Sindagi

Respected Sir,

We, the faculty of department of Botany along with BSc I Semester students kindly request you to give the permission to visit the water purification unit at Sindagi on 13/12/22 for Practical experimental demonstrations and field observations as it is made compulsory according to Rani Channamma University syllabus.


Therefore, we kindly request you to give the permission to visit.
Hope, the authority will consider and oblige.

Sindagi

Date: 12/12/22



Coordinator IQAC


Principal,
G.P.Porwal Arts, Comm. &
V.V.Salimath Sc. College
& P. G. Centre, SINDAGI

Yours Sincere

S.S.Muttinpendimath

DEPARTMENT OF BOTANY


J. P. Angadi

ಸ್ವೀಕೃತವಾಗಿದೆ

ಗುನಾಸ್ತ್ರ
ಪ್ರರಸಭೆ ಸಿಂಡಗಿ

12/12/2022


(35) 12/12/22

586 128


LIST OF STUDENTS VISITING WATER PURIFICATION UNIT SINDGI

SL NO	REGD NO.	STUDENTS NAME	SIGN
1.	S0003	PALLAVI KUMBARA	Pallavi
2.	S0010	SANIYA SALIMAPATEL BIRADAR	Saniya
3.	S0012	ASHWINI BASAVARAJ YATNAL	Ashwini
4.	S0013	SHASHIDHAR BIRADAR	Shashidhar
5.	S0014	SHIVALEELA PATIL	Shivaleela
6.	S0022	MALLAMMA BIRADAR	Mallamma
7.	S0023	AJAYAKUMAR HOSAMANI	Ajayakumar
8.	S0024	MD SADIQ SHAIKH	MD Sadiq
9.	S0026	LAKSHMI	Lakshmi
10.	S0029	DANAMMA S HARNAL	Danamma
11.	S0035	MAHESHWARI S MATHAPATI	Maheshwari
12.	S0042	MALLIKARJUN	Mallikarjun
13.	S0047	BAPUGOUDA	Bapugouda
14.	S0055	AKSHATA	Akshata
15.	S0057	SAMEENA NADAF	Sameena
16.	S0060	PRAMOD PATIL	Pramod
17.	S0061	MAHANTESH JERATAGI	Mahantesh
18.	S0065	NIDANOUSHEEN NADAF	Nidanousheen
19.	S0066	TAMKEEN ABDULRAJAK YALAGI	Tamkeen
20.	S0069	VINOD P CHALAVADI	Vinod
21.	S0070	SACHITH S K	Sachith
22.	S0074	RUTIKA RAMESH PANDIT	Rutika
23.	S0075	PUSHPALATA M D	Pushpalata
24.	S0078	SAVITRI.SHIVAPPA .DHANNUR	Savitri
25.	S0079	ALMAS J ANGADI	Almas

26.	S0080	SOYAL RAJAK BALAGANUR	Soyal
27.	S0083	MAHANTESH M CHIGARI	mahes
28.	S0085	SUSHMA BIRADAR	sushma
29.	S0089	VIVEKANAND.N.MUJAVAR	Vivek
30.	S0090	NEETA N PATTANASHETTI	Neeta
31.	S0091	ARNAZ ABDULHAMID SALODAGI	Arnaz
32.	S0092	BASAVARAJ MIRAGI	Basav
33.	S0094	APOORVA R KAMBALE	Apoorva
34.	S0099	AKSHA PARASHETTI	Aksha
35.	S0103	MALINGRAYA.S,YARAGAL	malena
36.	S0104	VIKAS.GADDAD	Vikas
37.	S0106	RAXITA M JOGUR	Raxita
38.	S0107	AFREEN BEGUM	Afreem
39.	S0110	RADHIKA.RAMESH.PANDIT	Radhika
40.	S0112	ARUN SHRISHAIL NAIKODI	Arun
41.	S0113	KAVERI,CHOUDRI	Kaveri
42.	S0114	ABDUL QADIR JELANI	Abdul


HEAD
Dept. of Botany
G.P.P. & V.V.S. College
SINDGI - 586 128


Co-ordinator IQAC
G. P. Porwal Arts, Comm & V. V. Salimath
Science College, SINDGI-586128. Dt:Vijayapur


Principal,
G. P. Porwal Arts, Comm. &
V. V. Salimath Sc. College,
SINDGI-586128. College Code:5224

COLLEGE ROLL NO: ~~130~~

UNIVERSITY NO: U15NB22S074

S.P.V.V.S
G.P.PORAWAL ARTS COMMERCE & V.V.SALIMATH
SCEINCE COLLEGE SINDAGI – 586128
DIST – VIJAYAPUR



RANI CHANNAMMA



UNIVERSITY, BELAGAVI



DEPARTMENT OF BOTANY

2022-23

This is Clarify that Kumari Rutika Pandit ^{1st}
semester Satisfactorily Completed the course of
Water Purification Unit report work in Botany, as
laid in the regulation of Rani Channamma
University Belagavi.


STAFF MEMBER INCHARGE


HEAD OF THE DEPARTMENT
G.P.P. & V.V.S. College
SINDGI - 586 128


Co-ordinator IQAC


Principal,

S.P.V.V.S
G.P.PORAWAL ARTS COMMERCE & V.V.SALIMATH
SCIENCE COLLEGE SINDAGI – 586128
DIST – VIJAYAPUR



RANI CHANNAMMA



UNIVERSITY, BELAGAVI



PROJECT REPORT

DEPARTMENT : BOTANY - 2022-23


DATE : 19-12-2022

NAME : RUTIKA PANDIT
SUBJECT : BOTANY-1
TITLE OF THE PROJECT: WATER PURIFICATION
CLASS : BSC 1ST SEM
REGISTER NO : U15NB22S074
ROLL NO : 72


HEAD
Dept. of Botany


Coordinator IQAC


SUBMITTED BY



DEPARTMENT OF BOTANY

POND WATER PURIFICATION

Title : One Day field visit to pond water purification Vidya nagar Sindagi. 13-12-2022

Introduction :-

Objectives : To aware all the botany Students about pond water purification practical knowledge.

Main Content :- As a part of Botany Curriculum And Department activity was department arranged one day study pond water purification in Vidya Nagar Sindagi. Tq Sindagi Dist –Vjayapur we and our teachers **Shailaja and Jyoti Medam** are selected this spot for our study of practical knowledge. The water utilized for drinking as well as irrigation **A.J.R Natikar Junior Engineering And Ajad Malad** are Explain in the pond water purification method.

The Student Of B.sc 1st Sem were activity participated in the Study tour all the students were taken the advantage of this curriculum based study tour all the students observed in the pond water purification method.



Municipal Water Treatment Processes

CONVENTIONAL SURFACE WATER TREATMENT

Conventional surface water treatment plants are still being used throughout the United States. They typically consist of several steps in the treatment process. These include: (1) Collection ; (2) Screening and Straining ; (3) Chemical Addition ; (4) Coagulation and Flocculation ; (5) Sedimentation and Clarification ; (6) Filtration ; (7) Disinfection ; (8) Storage ; (9) and finally Distribution.

Let's examine these steps in more detail.

Collection – The source water for a municipal surface water treatment plant is typically a local river, lake, or reservoir. There must be a method to get this water to the water treatment plant. Quite often, a series of pumps and pipelines transport the water to the treatment plant. Sometimes, as is the case of San Angelo, water from a reservoir such as Twin Buttes can be transported to the water treatment plant via a river. Twin Buttes Reservoir is one of the water sources for San Angelo. The water is released into Lake Nasworthy where it is transported down the Concho River to the water treatment plant



At the water plant, large pumps are used to transfer the water up to the treatment facility. Treatment facilities are often engineered to utilize gravity water flow as much as possible to reduce pumping costs.


Many water treatment plants utilize water from more than one source. Blending groundwater with surface water is a method often used to improve the quality of the final product.

Screening and Straining – If you think about surface water sources, i.e., lakes, rivers, and reservoirs, you realize they contain varying amounts of suspended and dissolved materials. This material may include turbidity, color, taste, odor, microorganisms, fish, plants, trees, trash, etc. The material may be organic or inorganic, suspended or dissolved, inert or biologically active, and vary in size from colloidal to a tree trunk. Some of these larger items can impede equipment in the treatment process, such as a tree limb getting stuck in a water pump impeller. So the first process in conventional water treatment is to screen or strain out the larger items.

HEAD
Dept. of Botany
V. V. Salimath College

Co-ordinator IQAC
G. P. Porwal Arts, Comm & V. V. Salimath

Principal,
G. P. Porwal Arts, Comm. &
V. V. Salimath Sc. College,



This is often accomplished using a large metal screen, often called a bar- screen, which is placed in front of the water source intake. Large items are trapped on the screen as the water passes through it. These screens must routinely be raked or cleaned off.

Chemical Addition – Once the pre-screened source water is received into the treatment plant, chemicals are added to help make the suspended particles that are floating in the water clump together to form a heavier and larger gelatinous particle, often called floc. In this process, a chemical is added that reacts with the natural alkalinity in solution to form an insoluble precipitate. There are many different chemicals on the market that are used in this process. These chemicals are called *coagulants*. One of the most common that has been used for many years is aluminum sulfate, or alum. Some other very



popular coagulants are ferrous sulfate, ferric chloride, sodium aluminate, activated silica, and compounds called polymers that are manufactured chemicals made up of repeated small units of low molecular weight combined into molecules with very large molecular weights. These polymers are classified as cationic polymers (positively charged), anionic polymers (negatively charged), and nonionic polymers (neutrally charged). Regardless of which coagulant or combination of coagulants is used, they must be mixed very well with the water before they can form a heavier floc.

Coagulation and Flocculation - A rapid mix unit is usually used where the coagulant is added to the water to provide a very quick and thorough mixing. The water mixing is then slowed to allow the water to come in contact with the forming floc and allow it to increase in size.

SSM



The continued mixing must be gentle to allow the floc to grow and gain weight, but fast enough to keep it in suspension until you are ready for it to settle in the clarifiers. The process of adding a chemical to cause the suspended material to “clump” into larger particles is called flocculation or coagulation. The treatment unit where coagulation and flocculation is performed is called the “flocculator”.

Sedimentation and Clarification – Once the flocculation process is complete, the water then passes over the weir in the flocculator and travels to the center of the clarifier, or sedimentation basin. Here, the water makes its way from the center of the clarifier to the saw tooth weir at the perimeter of the unit.

As the water makes its way towards the weir, the large floc particles are allowed to settle out to the bottom of the clarifier. A rake continuously travels across the bottom of the clarifier and scrapes the settled floc to the center of the unit. Pumps are used to pull the settled “sludge” out of the clarifier and send it to a sedimentation / disposal pond. The water that passes over the weir is collected and transferred to the filters. The reason clarification occurs before filtration is so the majority of suspended material can be removed prior to filtration, which avoids overloading the filters and thus allowing much more water to be filtered before the filters must be backwashed.

A handwritten signature in blue ink, appearing to be 'JSM', located below the text.



Filtration – Clarified water enters the filters from the top. Gravity pulls the water down through the filters where it is collected in a drain system at the bottom of the unit. There are many different types of materials (media) used in filters. The most common being sand and gravel. Many conventional plants are now using granular activated carbon as the media of choice because it not only provides excellent mechanical filtration of particulate matter, but also removes organic compounds which can cause taste and odor problems.

Disinfection – Once the water has gone through the filtration process, it is about as clear and clean as it can get. However, there may still be bacteria and viruses remaining. To ensure these are destroyed, there must be a disinfection process employed. The most common disinfection process used in the United States is chlorination. Chlorine comes in many different forms including chlorine gas (most common), chlorine dioxide, hypochlorite (bleach), and others. Whichever method is used, chlorine is added to the water in an amount to ensure all microorganisms are destroyed. Water plants monitor the chlorine levels continuously and very carefully in the treated water. They must add enough chlorine to

Handwritten signature



ensure thorough disinfection of the water, but avoid adding excesses that can cause taste and odor problems when delivered to the consumer.

Storage – Once the disinfection process is complete, the water is stored. Storage usually takes place in an underground storage tank called a “clear well”, and also in elevated storage tanks that are visible around town. There must always be an ample supply of water available in the event of emergencies. These can include power outages, fires, floods, etc.

Distribution – So how does the water come out of your kitchen tap? The stored water is pushed through underground pipelines all over town in what is called a “distribution system”. The distribution system consists of large water pumps at the treatment plant, overhead water storage tanks, large pipelines, smaller pipelines, fire hydrants, valves, and water meters in your front yard.

Note: *All of the treatment processes listed above are not necessary used at the San Angelo Water Treatment Plant. This document is meant to give a general description of processes typically used in the treatment of municipal water.*



[Handwritten signature]

[Handwritten signature]

[Handwritten signature]
HEAD
Dept. of Botany
G.P.P. & V.V.S. College
SINDGI - 586 128

[Handwritten signature]
Co-ordinator IQAC
G. P. Porwal Arts, Comm & V. V. Salimath
Science College, SINDGI-586128. Dt.Vijayapur

[Handwritten signature]
Principal,
G. P. Porwal Arts, Comm. &
V. V. Salimath Sc. College,
SINDGI-586128. College Code:5234